

Declaration of Conformity for FXR Series Inverter/Chargers

Purpose

The intent of this document is to specify that the OutBack models listed in the Scope below conform to the following standards for grid-interactive inverter/chargers.

This document supersedes any previous declarations for these OutBack models.

Scope

OutBack models covered by this Declaration of Conformity include the following.

- FXR2012E
- FXR2024E
- FXR2348E
- VFXR2612E
- VFXR3024E
- VFXR3048E



IMPORTANT:

This Declaration of Conformity covers only the models listed above. This Declaration does not cover any other models.

Directives

- RoHS: Directive 2011/65/EU — *“The restriction of the use of certain substances in electrical and electronic equipment”*
- LVD: 2006/95/EC — *“Electrical equipment designed for use within certain voltage limits”*
- EMC: 2004/10B/EC — *Electromagnetic Compatibility*

Certifications

This product is certified to the following standards:

- IEC 62109-1:2010 — Safety of Power Converters for use in Photovoltaic Systems (2010)
- EN 61000-6-1 — EMC Standard: Immunity for Residential, Commercial, and Light-Industrial Environments
- EN 61000-6-3 — EMC Standard: Emissions for Residential, Commercial, and Light-Industrial Environments
- EN 61000-3-3 — EMC Standard: Limitation of Voltage Changes, Voltage Fluctuations, and Flicker in Public Low-Voltage Supply Systems

Specification Conformity

Models FXR2024E, VFXR3024E, FXR2348E, and VFXR3048E are declared to conform to the following:

These inverter/charger models have grid-interactive functions. They are tested to certain limits for acceptable output voltage ranges, acceptable output frequency, total harmonic distortion (THD) and anti-islanding performance when the inverter exports power to a utility source. The OutBack inverter/charger models listed here are validated through compliance testing. The following specifications refer to exporting power to a simulated utility source of less than 1% voltage total harmonic distortion (THD).

- The THD of the root mean square (RMS) current is less than 5%.
- The output of the FXR inverter exceeds the minimum power factor of 0.85 with a typical power factor of 0.96 or better.



Declaration of Conformity for Radian Series Inverter/Chargers

The reconnection delay has a default setting of 1 minute. The settings for the reconnection delay and **Grid Interface Protection** are adjustable, but this is only available to operators with installer-level access. The reason for the limitation is that there are firm rules concerning acceptable voltage range, frequency range, clearance time during power loss, and reconnect delay when exporting power to the utility. The rules differ in different locations around the world, although generally it is expected that the settings cannot be altered by the end user. For this reason, the installer password must be changed from the default in order to get access to these settings. Once the password has been changed, the **Grid Interface Protection** settings can be accessed by using the installer password.

For programming navigation, see the *MATE3 System Display and Controller Owner's Manual*. For a full list of **Grid Interface Protection** default settings and available ranges, see the *FXR Series Operator's Manual*.

I hereby certify that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable requirements.



Harvey Wilkinson, General Manager

OutBack Power Technologies

Date: December 23, 2014

Contact Information

Address:	Corporate Headquarters 17825 – 59 th Avenue N.E. Suite B Arlington, WA 98223 USA	European Office Hansastrasse 8 D-91126 Schwabach, Germany
Telephone:	+1.360.435.6030 +1.360.618.4363 (Technical Support) +1.360.435.6019 (Fax)	+49.9122.79889.0 +49.9122.79889.21 (Fax)
Email:	Support@outbackpower.com	
Website:	http://www.outbackpower.com	

Notice of Copyright

Declaration of Conformity for FXR Series Inverter/Chargers © 2014 by OutBack Power Technologies.
All Rights Reserved.

Date and Revision

December 2014, Revision A

Part Number

907-0012-01-00 Rev A



Masters of the Off-Grid.™ First Choice for the New Grid.